Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

PTB

(1) # EC-TYPE-EXAMINATION CERTIFICATE

(Translation)

(2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres - **Directive 94/9/EC**

(3) EC-type-examination Certificate Number:

PTB 00 ATEX 2048 X

(4) Equipment: Cylindrical inductive sensors, types NC... and NJ...

(5) Manufacturer: Pepperl + Fuchs GmbH

(6) Address: D-68307 Mannheim

(7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

(8) The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report PTB Ex 00-29206.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014:1997 **EN 50020:1994**

(10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

(11) This EC-type-examination Certificate relates only to the design and construction of the specified equipment in accordance with Directive 94/9/EC. Further requirements of this Directive apply to the manufacture and supply of this equipment.

(12) The marking of the equipment shall include the following:

Ex II 2 G EEx ia IIC T6

Zertifizierungsstelle Explosionsschutz
By order:

Braunschweig, September 26, 2000

Dr.-Ing. U. Johannsmeyer
Regierungsdirektor

PHYSIKALISCH-TECHNISCHE BUNDESANSTALT 24

(13) # SCHEDULE

(14) ## EC-TYPE-EXAMINATION CERTIFICATE PTB 00 ATEX 2048 X

(15) Description of equipment

The cylindrical inductive sensors, types NC... and NJ...are used to convert displacements into electrical signals.

The cylindrical inductive sensors may be operated with intrinsically safe circuits certified for categories and explosion groups [EEx ia] IIC or IIB resp. [EEx ib] IIC or IIB. The category as well as the explosion group of the intrinsically safe cylindrical inductive sensors depends on the connected supplying intrinsically safe circuit.

Electrical data

Evaluation and
supply circuit..... type of protection Intrinsic Safety EEx ia IIC/IIB
resp. EEx ib IIC/IIB
only for connection to certified intrinsically safe circuits
maximum values:

type 1	type 2	type 3	type 4
U_i = 16 V	U_i = 16 V	U_i = 16 V	U_i = 16 V
I_i = 25 mA	I_i = 25 mA	I_i = 52 mA	I_i = 76 mA
P_i = 34 mW	P_i = 64 mW	P_i = 169 mW	P_i = 242 mW

The assignment of the type of the connected circuit to the maximum permissible ambient temperature and the temperature class as well as the effective internal reactances for the individual types of cylindrical inductive sensors is shown in the following table:

Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

SCHEDULE TO EC-TYPE-EXAMINATION CERTIFICATE PTB 00 ATEX 2048 X

types	C_i	L_i	type 1			type 2			type 3			type 4		
			maximum permissible ambient temperature in °C for application in temperature class											
	[nF]	[µH]	T6	T5	T4-T1	T6	T5	T4-T1	T6	T5	T4-T1	T6	T5	T4-T1
NCB1,5...M...N0...	90	100	74	89	100	69	84	100	51	66	85	39	54	67
NCB2-12GK...-N0...	90	100	73	88	100	69	84	100	51	66	80	39	54	61
NCB2-12GM...-N0...	90	100	76	91	100	73	88	100	62	77	81	54	63	63
NCN4-12GK...-N0...	95	100	73	88	100	69	84	100	51	66	80	39	54	61
NCN4-12GM...-N0...	95	100	76	91	100	73	88	100	62	77	81	54	63	63
NCB5-18GK...-N0...	95	100	73	88	100	69	84	100	51	66	80	39	54	61
NCB5-18GM...-N0...	95	100	76	91	100	73	88	100	62	77	81	54	63	63
NCN8-18GK...-N0...	95	100	73	88	100	69	84	100	51	66	80	39	54	61
NCN8-18GM...-N0...	95	100	76	91	100	73	88	100	62	77	81	54	63	63
NCB10-30GK..-N0...	105	100	73	88	100	69	84	100	51	66	80	39	54	61
NCB10-30GM..-N0...	105	100	76	91	100	73	88	100	62	77	81	54	63	63
NCN15-30GK...-N0...	110	100	73	88	100	69	84	100	51	66	80	39	54	61
NCN15-30GM...-N0...	110	100	76	91	100	73	88	100	62	77	81	54	63	63
NJ 0,2-10GM-N...	20	50	73	88	100	68	83	100	49	64	67	36	42	42
NJ 0,8-4,5-N...	30	50	73	88	100	68	83	100	49	64	67	36	42	42
NJ 0,8-5GM-N...	30	50	73	88	100	68	83	100	49	64	67	36	42	42
NJ 1,5-6,5...-N...	30	50	73	88	100	68	83	100	49	64	67	36	42	42
NJ 1,5-10GM-N-Y...	20	50	73	88	100	68	83	100	49	64	67	36	42	42
NJ 1,5-8GM-N...	30	50	73	88	100	68	83	100	49	64	67	36	42	42
NJ 1,5-8-N...	20	50	73	88	100	68	83	100	49	64	67	36	42	42
NJ 1,5-18GM-N-D...	50	60	76	91	100	73	88	100	62	77	81	54	63	63
NJ 2-11-N...	45	50	73	88	100	66	81	100	45	60	89	30	45	74
NJ 2-11-N-G...	30	50	76	91	100	73	88	100	62	77	81	54	63	63
NJ 2-12GK-N...	45	50	73	88	100	69	84	100	51	66	80	39	54	61
NJ 2-12GM-N...	30	50	76	91	100	73	88	100	62	77	81	54	63	63
NJ 2-14GM-N...	30	50	76	91	100	73	88	100	62	77	81	54	63	63
NJ 2,5-14GM-N...	30	50	76	91	100	73	88	100	62	77	81	54	63	63
NJ 4-12GK-N...	45	50	73	88	100	69	84	100	51	66	80	39	54	61
NJ 4-14GK-N...	45	50	73	88	100	69	84	100	51	66	80	39	54	61
NJ 4-12GM-N...	45	50	73	88	100	68	83	100	49	64	67	36	42	42
NJ 4-30GM-N-200...	70	100	73	88	100	66	81	100	45	60	89	30	45	74
NJ 5-10-11-N...	70	100	73	88	100	66	81	100	45	60	78	30	45	57
NJ 5-11-N...	45	50	72	87	100	65	80	100	42	57	82	26	41	63
NJ 5-18GK-N...	70	50	73	88	100	69	84	100	51	66	80	39	54	61
NJ 5-18GM-N...	70	50	76	91	100	73	88	100	62	77	81	54	63	63
NJ 6-22-N...	130	100	73	88	100	69	84	100	51	66	80	39	54	61
NJ 8-18GK-N...	70	50	73	88	100	69	84	100	51	66	80	39	54	61

types	C_i [nF]	L_i [µH]	type 1			type 2			type 3			type 4		
			maximum permissible ambient temperature in °C for application in temperature class											
			T6	T5	T4-T1	T6	T5	T4-T1	T6	T5	T4-T1	T6	T5	T4-T1
NJ 8-18GM-N...	70	50	76	91	100	73	88	100	62	77	81	54	63	63
NJ 10-22-N...	130	100	73	88	100	69	84	100	51	66	80	39	54	61
NJ 10-30GK...-N...	140	100	73	88	100	69	84	100	51	66	80	39	54	61
NJ 10-30GM-N...	140	100	76	91	100	73	88	100	62	77	81	54	63	63
NJ 15-30GK...-N...	140	100	73	88	100	69	84	100	51	66	80	39	54	61
NJ 15-30GM-N...	140	100	76	91	100	73	88	100	62	77	81	54	63	63
NJ 25-50-N...	150	140	73	88	100	69	84	100	51	66	80	39	54	61
NJ 20-40-N...	140	140	73	88	100	69	84	100	51	66	80	39	54	61

(16) Test report PTB Ex 00-29206

(17) Special conditions for safe use

1. For the application within a temperature range of -60 °C to -20 °C the cylindrical inductive sensors, types NC... and NJ... must be protected against damage due to impact by mounting into an additional housing.
2. The connection facilities of the cylindrical inductive sensors, types NC... and NJ... shall be installed as such that at least a degree of protection of IP20 according to IEC-publication 60529:1989 is met.
3. The assignment of the type of the connected circuit to the maximum permissible ambient temperature and the temperature class as well as the effective internal reactances for the individual types of cylindrical inductive sensors is shown in the table given under item (15) of this EC-type-examination certifcate.
4. Inadmissible electrostatic charge of parts of the metal housing has to be avoided for the following types of cylindrical inductive sensors. Dangerous electrostatic charges of parts of the metal housing can be avoided by grounding of these parts whereas very small parts of the metal housing (e.g. screws) don't need to be grounded:

NCB1,5...M...N0...	NJ 1,5-6,5...-N...	NJ 4-30GM-N-200...
NCB2-12GM...-N0...	NJ 1,5-10GM-N-Y...	NJ 5-11-N-545...
NCN4-12GM...-N0...	NJ 1,5-8GM-N...	NJ 5-11-N-G...
NCB5-18GM...-N0...	NJ 1,5-8-N...	NJ 5-18GM-N...
NCN8-18GM...-N0...	NJ 1,5-18GM-N-D...	NJ 6-22-N-G...

SCHEDULE TO EC-TYPE-EXAMINATION CERTIFICATE PTB 00 ATEX 2048 X

NCB10-30GM..-N0...	NJ 2-11-N-G...	NJ 8-18GM-N...
NCN15-30GM...-N0...	NJ 2-12GM-N...	NJ 10-22-N-G...
NJ 0,2-10GM-N...	NJ 2-14GM-N...	NJ 10-30GM-N...
NJ 0,8-4,5-N...	NJ 2,5-14GM-N...	
NJ 0,8-5GM-N...	NJ 4-12GM-N...	

(18) Essential health and safety requirements

Met by the standards mentioned above

Zertifizierungsstelle Explosionsschutz
By order:

Dr.-Ing. U. Johannsmeyer
Regierungsdirektor

Braunschweig, September 26, 2000